



We help ideas meet the real world



Compliance Statement

No. 2011-269

Connecting Hardware, Category 6A

Company

HCS - HES Cabling Systems
Turgutreis Mah. Barbaros Cad.
Giyimkent Kooperatif Ici Vadi Bulvari No:1
Esenler
Istanbul
Turkey

Product description

Screened Category 6A RJ45 Jack and Patch Panel characterised up to 500 MHz, 100 Ω

Product identification

- 8P8C RJ-45 Shielded Augmented Category 6 Keystone Jack. Part Number: J6A-0082X (X denotes color)
- Keystone Jack 19" Blank Metal Patch Panel. Part Number: P00-0xx20-1U (xx denotes number of ports)

Generic cabling and cabling components standards - Category 6A connector requirements

- ISO/IEC 11801:2011 (Ed. 2.2)
- IEC 60603-7-51:2010
- EN 50173-1:2011
- EN 50173-2:2007 including amendment A1:2010
- ANSI/TIA-568-C.2:2009

including all connector alien crosstalk parameters (PS ANEXT and PS AFEXT)

Technical report

DELTA-N313056, DANAK-19J2598

EC Cabling product ID

5273

Certificate valid until

18 October 2012

This product has been tested by EC Cabling Group of DELTA and complies with the electrical requirements of the above specified standards and "Terms and conditions for use of the EC VERIFIED marking on generic cabling products", DQP231006. The testing included measurement of NEXT with a compliant test plug and calculation of all the 14 test cases in both measurement directions. The product takes part in a maintenance of certification schedule, which implies that DELTA EC Cabling performs a quality audit of the manufacturer's production and QA sites. The maintenance testing of the product is performed on a sample basis once a year.

Hørsholm, 18 October 2011

Erik Bech
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable



TEST Reg. no. 19